

Permit to Operate Temporary Mobile and Fixed Food & Beverage concession

- Applications to obtain a permit to operate a temporary mobile and fixed food and beverage concession may be obtained at the Swanzey Fire Station, 34 Main Street, Monday through Friday, between the hours of 08:00am and 4:00pm or by calling 358-6455 and leaving a voice mail with your name, address and telephone number.
- NFPA 1 Uniform Fire Code, Chapter 1.12 Permits and Approvals
- Commercial cooking operations will be installed and operated and maintained in accordance with the NH State Fire Code, and NFPA 96, including but not limited to the following:
 - Residential cooking equipment used in commercial operations will be considered commercial equipment.
 - Cooking equipment used in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, pavilions, tents, or any form of roofed enclosure, shall comply with NFPA 96.
 - Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of NFPA 96.
 - Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct, shall be protected by fire extinguishing equipment.
 - All solid fuel cooking equipment served by hoods and duct systems shall be separate from all other exhaust systems.
 - Solid fuel cooking appliances that produce grease laden vapors shall be protected by listed fire-extinguishing equipment.
 - A type K fire extinguisher is required in all cooking areas.
- LP Gas Installations:
 - All LP gas installations shall be installed in accordance with NFPA 54 and NFPA 58 and shall include but not be limited to the following:
 - No storage of unused LP cylinders or tanks will be permitted in any vehicle.
 - Fuel gas delivery systems will be approved by the authority having jurisdiction.
 - All LP tanks and containers not permanently attached to a vehicle will be a minimum of 10 feet from any ignition source.
 - All LP tanks and containers not permanently attached to a vehicle will be secured in an upright position.
 - All fuel gas piping, tanks, and containers shall be protected from damage, tampering and vehicular traffic in accordance with the requirements of NFPA 54, National Fuel Gas Code.
 - All LP gas appliance and piping installations, other than self-contained units shall be completed by a NH licensed gas fitter.